

CERTIFICATE OF COMPLIANCE

January 2015

Invisi-Gard Screens & Breezway Altair Louvres Bushfire Compliant

The Breezway Altair Louvre window with 6mm toughened glass blades in an Alspec frame with Invisi-Gard stainless steel screens have been tested by an independent testing authority to AS1530.8.1 (BAL40) achieving a pass result.

A minimum distance of 85mm between the Invisi-Gard screen mesh and 6mm toughened Louvre blades is required to achieve compliance.

The combined products have been tested and is restricted to a maximum height of 2400mm and 1000mm in width. Report number: FCO-3147A.

The requirements under AS3959-2009 standard for screening of openable parts of "windows" shall still apply to tested systems. Hence stainless steel screens are required to all Louvre window openings.

Further detailed information and test reports can be obtained from Alspec upon request.

breezway



Aluminium Specialties Group Pty Ltd

3 Alspec Place, Eastern Creek NSW 2766
PO Box 262, Horsley Park NSW 2175
Phone: 02 9834 9500 | Sales: 1300 ALSPEC
Fax: 02 9834 9532
www.alspec.com.au
ABN: 63 001 252 259

alspec
ALUMINIUM SYSTEMS
SPECIALISTS